

Mr Jan Jordaan  
Key Account Development Manager  
Copalcor (PTY) LTD  
Private Bag X030  
WADEVILLE, GERMISTON  
1422

Date:  
29 March 2012

Enquiries:  
Tel +27 43 703 5380

Dear Mr Jordaan

### **APPROVAL TO MANUFACTURE COPPER EARTHROD AND BRASS CLAMP**

It gives me great pleasure to inform you that Copalcor (PTY) Ltd has been evaluated and approved as a manufacturer of the following products:

1. Threadless copper earth rod, 1500 x 16 dia. mm as per Eskom buyers guide DDT3091, SAP 0168669
2. Earth rod clamp, brass for 16mm rod as per Eskom buyers guide DDT3093, SAP 01655559.

Copalcor have complied with the requirements as detailed in SABS 1063:2011, with the exception of the Environmental test as detailed in section 6.6 of the standard. Copalcor will be listed as an approved manufacturer on the Eastern Cape Operating Unit's material database, with immediate effect. Copalcor will be granted a period of one month i.e. 1 May 2012, to submit the environmental test results. Failure to submit or negative test results will result in the approval being withdrawn.

Copalcor have submitted their unique identification mark as follows:

1. Earth rod shall bear the marks: **COPALCOR SABS SANS1063 DATE ECOR**
2. Earth clamp: **ECOR**



## Post Acceptance compliance

- Failures and non-compliance of future samples of the product will be dealt with via investigative routes and non-conformance procedures, which will negatively affect the working relationship or result in removal from the Eastern Cape Operating Unit material database.
- The Buyers Guide drawings and Eskom Specifications change from time to time. The onus lies with the Manufacturer to ensure that the latest revision is applied. Drawings and specifications are accessible on the Eskom Distribution Technology web site. Application for access to the DT Home Page may be made via Johan Scholtz, 011 629 5624. Alternatively these may be requested from the Technology and Quality Department.
- Indelible marking is an Eskom requirement. All future products supplied to Eskom shall have an indelible mark. Copalcor marking identification has been submitted as **ECOR**.

Yours sincerely

A handwritten signature in black ink, appearing to read 'Denise Hewitt', enclosed within a circular scribble.

Denise Hewitt  
**Senior Technician: Technology and Quality**  
**Eastern Cape Operating Unit**